

January 14th, 2021

ph: 910-893-7547

fax: 910-893-9371

Samantha Holley
814 Brooks Mangum Rd
Cameron, NC 28326

RE: Existing Tank Application # BRES2012-0069-3094 Marks Rd

Ms. Holley,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary Tee with Filter

4. Other – Locate and expose all property irons. Uncover D-Box

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



REHS

Mark Osborne, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

MO/kh
Copy - Central Permitting