

January 20, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Pamela White
348 Monroe Lane
Erwin, NC 28339

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: BRES2012-0074

Ms. White:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- _____ 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- _____ 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- _____ 3. Directions not clear to property (*\$25.00 fee incurred*)
- _____ 4. Property needs only brush or vegetation removed
- _____ 5. Driveway not shown on site plan
- _____ 6. Backhoe pits required
- _____ 7. **Other- Soil scientist proposal required or lot shall be combined with owners neighboring lot. Existing lot does not have sufficient available space for full septic and repair with front power setback, rear FEMA floodplain, and existing stream. Provide soil report to Central Permitting for file for lot recombination and revise site plan accordingly.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting