

January 11th, 2021

Alvaro R Garcia Estrada
748 Johnsonville School Rd
Cameron, NC 28326

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

RE: Harnett County Land Use Application #BRES2012-0076

Mr. Estrada

The Harnett County Department of Public Health, Environmental Health Division on 1/11/2021 evaluated the above referenced property at the site designated on the plat/site plan that accompanied your improvement permit application. According to your application requesting, 3 bedroom, 27' x 49' DWMH the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the septic system requested. Therefore, your request for an improvement permit is **DENIED**. The site is denied based on the following:

- 15A NCAC 18A.1950a {16} - Any building structure must be 5' from any part of septic system.
- 15A NCAC 18.1945{b} - Each lot shall have original septic system plus repair area. Unavailable space for an initial septic system and complete repair area.
- 15A NCAC 18A.1950 {10} - Any building to be 5' from septic tank and/or drain line.
- 15A NCAC 18A.1950{c} - Nitrification fields and repair areas shall not be located under paved areas or areas subject to vehicular traffic.

Call me to discuss further in detail. If you should have any questions or concerns, I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,



Mark Osborne, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

MAO/KH