

HTE #: BRES2012-0087

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Rodney and Patrick Duke Phone #: (704) 819-7398

Address: 665 Main St #17 Lillington, NC 27546

Name of Mobile Home Park or S/D: Lot #2 T Ravon Stone Etux

Name of Owner (if different): Gregory Scott Varner

Address of Owner (if different): 71 Ester Stone Ln. Coats, NC 27521

Property Location (State Road name and #): 71 Ester Stone Ln. (NC 55 E.)

Purpose of Inspection: 26.8'x52' 3-Bedroom DWMH - Approx. location of former foudation

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

01/12/2021

Date

OPERATIONS PERMIT

Name: (owner) RAYON STONE New Installation Septic Tank
Property Location: SR# 2010 Repairs Nitrification Line
Subdivision _____ Lot # Parcel B
TAX ID# _____ Quadrant # _____
Contractor: Arnold Chappell Registration # _____
Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain: _____ Linear feet

PERMIT NO. 12273 Date: 4-30-77
Inspected by: James E. Mendenhall, Jr.
Environmental Health Specialist

