

OPERATIONS PERMIT

Name: (owner) Ramon Stone New Installation Septic Tank
 Property Location: SR# 2010 Repairs Nitrification Line
 Subdivision _____ Lot # Parcel B
 TAX ID# _____ Quadrant # _____
 Contractor: Arnold Chappell Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.


Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain: _____ Linear feet

PERMIT NO. 12273 Date: 4-30-97
 Inspected by: James E. Montaneda, Jr.
 Environmental Health Specialist



HARNETT COUNTY HEALTH DEPARTMENT

No 12273

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) T RAYON STONE
Property Location: SR# 2010 Bennet H Road.
New Installation
Septic Tank
Repairs
Nitrification Line

Subdivision _____ Lot # Parcel B

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 4.02 acres

Basement with Plumbing: [] Garage: []

Water Supply: [x] Well [x] Public [] Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: [x] Conventional [] Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 4 exact length of each ditch 160 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain Required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 4-21-97

Signed: James E. M... Environmental Health Specialist



SR 2010B