

January 11th, 2021

Ryan McNeil
1606 Hoover Rd,
Sanford, NC 27332

RE: Existing Tank Application # SFD2012-0093

Mr. McNeil

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other – Septic Tank lid needs to be replaced.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

MAO/KH
Copy - Central Permitting