



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

5/3/2023

SUBJECT: BRES2012-0093
BUILDING RESIDENTIAL

To: MCNEILL RYAN LAWRENCE

Here are the results of all Inspections located at **1606 HOOVER RD:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 8/10/2022
Completed Date/Time: 8/10/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUNDATION
Scheduled Date/Time: 8/18/2022
Completed Date/Time: 8/18/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 12/29/2022
Completed Date/Time: 12/29/2022
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes:

Strap garage door headers to top plate per portal frame detail. Strap stud columns. Missing air barriers if insulating upstairs. Ramset bearing walls at stairs. Must have door from stairwell to garage. Missing bracing on trusses. Must use correct nails in truss hangers. Leave short teco nails on ground after replacing.

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 1/23/2023
Completed Date/Time: 1/23/2023
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes:

Must have separated exit from stairs to outside. Need door from garage to stair landing. Missing air barriers, blocking at top of knee walls, and insulation baffles.

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 2/1/2023
Completed Date/Time: 2/1/2023
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: INSULATION
Scheduled Date/Time: 2/7/2023
Completed Date/Time: 2/7/2023
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**

Scheduled Date/Time: 4/20/2023

Completed Date/Time: 4/20/2023

Inspector: Steven Gazlay

Result: DISAPPROVED

Remarks:

Notes: Need handrails, missing windload sticker on garage door. Need co/mo detector. Need child locks if sills are less than 24" from floor. Need TR outlets.

Inspection Type: FINAL**

Scheduled Date/Time: 4/25/2023

Completed Date/Time: 4/25/2023

Inspector: John B Kokoszka

Result: DISAPPROVED

Remarks:

Notes: Inspector JTH changed the inspection assignment from JTH to JBK

Need a CO/ smoke combo unit

Inspection Type: FINAL**

Scheduled Date/Time: 4/27/2023

Completed Date/Time: 4/27/2023

Inspector: Steven Gazlay

Result: APPROVED

Remarks:

Notes: