

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

2-5-1952
1402
No 13432

OPERATIONS PERMIT

Name: (owner) Richard J Vann New Installation Septic Tank
Property Location: SR# 1767 OLD STAGE Repairs Nitrification Line
Subdivision Kennedy Acres Lot # 11
TAX ID# _____ Quadrant # _____
Contractor: Bandoot Septic Registration # _____

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 50' ft.


Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface Drainage Field: No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-20 in.
French Drain: — Linear feet

Date: 11-28-01

PERMIT NO. 16977

Inspected by: James E. Merchant
Environmental Health Specialist



HARNETT COUNTY HEALTH DEPARTMENT

No 16997

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) RICHARD J VANN

New Installation

Septic Tank

Property Location: SR# 1769 OLD STAGE

Repairs

Nitrification Line

Subdivision Kennedy Acres Lot # 11

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: .69 Acre

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain Required: _____ Linear feet

Date: 4-5-01

Signed: James E. Markant III, M.S.
Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

