

HTE #: BRES2009-0070

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Brenton Underwood Phone #: (919) 586-6030

Address: 216 Sherman Dr Fuquay Varina, NC 27526

Name of Mobile Home Park or S/D: Sherman Pines - Lot 12

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 216 Sherman Dr. (US 401 N.)

Purpose of Inspection: 16'x24' hybrid pool w/deck around - 15ft min setback - verified via GPR

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM


Signature of Environmental Health Specialist

12/30/2020
10/16/2020
Date