## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 230 WHITT CT. (JAMES DORAIS - SA 1440) ISSUED TO: BLASS CUMMINOS SUBDIVISION NIZICUS CREZK FARM LOT # 107 REPAIR | EXPANSION NEW 🔯 Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 4-325200m 721x77' 577 Proposed Wastewater System Type: 25% NESSOCTIONS STS Projected Daily Flow: 486 GPD Number of bedrooms: 4 Number of Occupants: 8 max Basement Yes No Pump Required: Yes No May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well of feet Five years Permit valid for: Permit conditions: No expiration 07/17/2020 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout ISSUED TO: BRAD CUMMINOS PROPERTY LOCATION: 230 WHIT CT. (JAMES SOMIS) SUBDIVISION NEILLS CREEK FARM LOT # 107 Facility Type: 4Br 72'x77'55 > New Expansion Repair Basement Fixtures? Yes Basement? Yes No No 25% REDOCTION STOTE (Initial) Wastewater Flow: 400 GPD Type of Wastewater System\*\* (See note below, if applicable ) 25% NESWETTON STS. (Repair) Installation Requirements/Conditions Number of trenches 3 Trench Spacing: \_\_\_\_\_ Feet on Center Septic Tank Size 1250 gallons Exact length of each trench 115 Soil Cover: 6 inches Pump Tank Size \_\_\_\_\_gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 16-18 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. \_\_\_\_ ~ inches below pipe Aggregate Depth: inches above pipe Conditions: MA inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Man and Date: 07/17/2020 Authorized State Agent: Construction Authorization Expiration Date: 07/17/2025 ANDREW CURIN

## Harnett County Department of Public Health Site Sketch

