

January 26th, 2021

Norma Owen  
4209 Smith Rd  
Sanford, NC 27330

**RE: Existing Tank Application # BRES2101-0019**

Ms. Owen,

An attempt was made to evaluate your property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other – **Risers needed on septic tank. Well needs new cap or needs to be abandoned.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

MO/kh  
Copy - Central Permitting