

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

January 29th, 2021

Brandon Smith
1607 Clayhole Rd
Dunn, NC 28334

RE: Existing Tank Application # BRES2101-0025

Mr. Smith,

An attempt was made to evaluate your property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal and D-Box (\$25.00 fee incurred).**
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other –

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

MO/kh
Copy - Central Permitting