

HTE #: BRES2101-0025

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: Brandon Smith

Phone #: 910-890-2923

Address: 1607 Clayhole Rd, Dunn

Name of Mobile Home Park or S/D: \_\_\_\_\_

Name of Owner (if different): Glen Coleman

Address of Owner (if different): 1144 Darroch Rd, Lillington NC (SR1128)

Property Location (State Road name and #): 1144 Darroch Rd, Lillington NC (SR1128)

Purpose of Inspection: Bathroom Addition

**The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.**

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

  
Signature of Environmental Health Specialist

2-9-21  
Date