



Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

February 12, 2021

ph: 910-893-7547

fax: 910-893-9371

Gwendolyn Bass
1054 Jesse Rd
Broadway, NC 27505

RE: Existing Tank Application # BRES2102-0005

Mrs. Bass

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other – Septic Tank lid needs to be replaced.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Mark Osborne REHS
Environmental Health Program Specialist
Harnett County Department of Public Health

MO/KH
Copy - Central Permitting