

March 8, 2021

Juana Mejia  
1696 Prospect Church Road  
Dunn NC 28334

**RE: Existing Tank Application # BRES2102-0040**

Ms. Mejia:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary T

4. **Other – Disapproved-Septic tank not uncovered for inspections and lids not exposed. Flagged structures (2) appear to take a significant portion of rear of property. Soil Scientist proposal shall be submitted verifying 5ft setback from existing septic system and available space of the property for required septic repair. Submit Soil Scientist Report for approval.**

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc  
Copy - Central Permitting