

March 25, 2021

ph: 910-893-7547

fax: 910-893-9371

KW Quality Trades

RE: Existing Tank Application #BRES2102-0053

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal.

2. Have system pumped out

3. Replace Sanitary Tee with Filter

4. Other – Due to the location of the existing septic Drain Lines, we can not approve a deck any larger than 10 foot off the back of the house.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Program Specialist
Harnett County Department of Public Health

MO/KH

Copy - Central Permitting