



**Harnett County**  
108 EAST FRONT STREET  
LILLINGTON, NC 27546  
Phone:  
Fax:

5/13/2021

**SUBJECT: BRES2102-0060**  
**BUILDING RESIDENTIAL**

To: David Perez

Here are the results of all Inspections located at **47 DEER VIEW:**

Inspection Type: FOOTING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Slade Burton Lawson III  
Result:  
Remarks:  
Notes:

Inspection Type: ADDRESS  
Scheduled Date/Time: 3/2/2021  
Completed Date/Time: 3/2/2021  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks:  
Notes: 47 DEER VIEW SANFORD 27332.

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 3/15/2021  
Completed Date/Time: 3/15/2021  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Inspector SBL changed the inspection assignment from SBL to SPG  
Ok to side and trim. Ok to pour footer for wall. Missing plumbing test. Electrical not roughed in.  
Pipe water heater blow off to exterior.  
Ok to side and trim. Ok to pour footer for wall. Missing plumbing test. Electrical not roughed in.  
Pipe water heater blow off to exterior.





**Harnett County**  
108 EAST FRONT STREET  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 3/19/2021  
Completed Date/Time: 3/19/2021  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes: Inspector SBL changed the inspection assignment from SBL to SPG

Inspection Type: WATER CONNECTION  
Scheduled Date/Time: 4/30/2021  
Completed Date/Time: 4/30/2021  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes: Inspector SBL changed the inspection assignment from SBL to SPG

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time: 4/30/2021  
Completed Date/Time: 4/30/2021  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Inspector SBL changed the inspection assignment from SBL to SPG  
Install backwater valve.

Inspection Type: ZONING  
Scheduled Date/Time: 5/4/2021  
Completed Date/Time: 5/4/2021 10:15 AM  
Inspector: Kyle Holder  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time: 5/4/2021  
Completed Date/Time: 5/4/2021  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes: Inspector SBL changed the inspection assignment from SBL to SPG





**Harnett County**  
108 EAST FRONT STREET  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: MFH FINAL\*\*  
Scheduled Date/Time: 5/5/2021  
Completed Date/Time: 5/5/2021  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes: Inspector SBL changed the inspection assignment from SBL to SPG