



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

9/23/2025

SUBJECT: **BRES2103-0016**
BUILDING RESIDENTIAL

To: Kenneth Duffton Johnson

Here are the results of all Inspections located at **301 DENIM DR:**

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time: 8/20/2021
Completed Date/Time: 8/20/2021
Inspector: Scott Guy
Result: CANCELLED
Remarks:
Notes: Per Snow Bowden when foundation is approved please schedule him a zoning inspection.
Contractor to open flooring areas to verify foundation repairs

Inspection Type: FOUNDATION
Scheduled Date/Time: 8/23/2021
Completed Date/Time: 8/23/2021
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: SLAB
Scheduled Date/Time: 9/16/2021
Completed Date/Time: 9/16/2021
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes: Footing under addition

Inspection Type: FOUNDATION
Scheduled Date/Time: 9/29/2021
Completed Date/Time: 9/29/2021
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes: cus advised this needs to be looked at again

Inspection Type: ROUGH IN
Scheduled Date/Time: 10/14/2021
Completed Date/Time: 10/14/2021
Inspector: Brad Sutton
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/13/2021 11:10 AM Kenneth Johnson

Contact Name: Kenneth Johnson
Site Address: 301 DENIM DR
Phone: 2147556992
e-Mail: duffyjohnson@outlook.com

Plumbing tests not on. Set tubs and pans. Install bath fans and vents. Hanger joist at living room. Foam hole in floor. Attic access and unit platform. Test gas system. Label gas lines



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 10/14/2021
Completed Date/Time: 10/14/2021
Inspector: Brad Sutton
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/13/2021 11:09 AM Kenneth Johnson

Contact Name: Kenneth Johnson
Site Address: 301 DENIM DR
Phone: 2147556992
e-Mail: duffyjohnson@outlook.com

Inspection Type: ROUGH IN
Scheduled Date/Time: 12/9/2021
Completed Date/Time: 12/10/2021
Inspector: Deen Taylor
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 12/8/2021 2:53 PM Kenneth Johnson
Plumbing rough in to complete all trades rough in
Contact Name: Kenneth Johnson
Site Address: 301 DENIM DR Erwin NC
Phone: 2147556992
e-Mail: duffyjohnson@outlook.com

Still no test on water drain lines. All holes in top and bottom plate and floor must be fire blocked.

Inspection Type: ROUGH IN
Scheduled Date/Time: 12/14/2021
Completed Date/Time: 12/14/2021
Inspector: Deen Taylor
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes:



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION
Scheduled Date/Time: 1/10/2022
Completed Date/Time: 1/10/2022
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 1/10/2022
Completed Date/Time: 1/10/2022
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes: PLUMBING

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 2/25/2022
Completed Date/Time: 2/25/2022
Inspector: Deen Taylor
Result: DISAPPROVED
Remarks:
Notes: Meter base damage. Interior panel missing cover. Receptacles missing in master and back spare bathroom

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 3/15/2022
Completed Date/Time: 3/15/2022
Inspector: Deen Taylor
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 3/12/2022 6:52 PM Kenneth Johnson

Contact Name: Kenneth Johnson
Site Address: 301 DENIM DR
Phone: 2147556992
e-Mail: duffyjohnson@outlook.com



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**
Scheduled Date/Time: 6/3/2022
Completed Date/Time: 6/3/2022
Inspector: Deen Taylor
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 5/26/2022 9:41 PM Kenneth Johnson

Contact Name: Kenneth Johnson
Site Address: 301 DENIM DR
Phone: 2147556992
e-Mail: duffyjohnson@outlook.com

Rear steps not installed. Need access door to crawl. Label breaker #5

Inspection Type: FINAL**
Scheduled Date/Time: 6/7/2022
Completed Date/Time: 6/22/2022
Inspector: Deen Taylor
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 6/6/2022 10:49 AM Kenneth Johnson

Contact Name: Kenneth Johnson
Site Address: 301 DENIM DR
Phone: 2147556992
e-Mail: duffyjohnson@outlook.com