

March 26, 2021

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Tylor Howard  
280 Gwendolyn Way  
Fuquay-Varina, NC 27526

ph: 910-893-7547  
fax: 910-893-9371

**RE: Existing Tank Application # BRES2103-0051**

Mr. Howard:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

\_\_\_ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

\_\_\_ 2. Have system pumped out

\_\_\_ 3. Replace Sanitary T

**X 4. Other – Disapproved - Proposed structure encroaches on septic setbacks. 5ft minimum setback required off septic field (marked onsite). Revise paperwork accordingly for approval.**

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc  
Copy - Central Permitting