

March 31st, 2021

Greg Culp
50 Ellie Court
Fuquay Varina, NC 27526

RE: Existing Tank Application # BRES2103-0053

Mr. Culp,

An attempt was made to evaluate your property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal and D-Box (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other – Denial of proposed deck. Septic encroachment of existing unpermitted pool and proposed deck. 5ft setback required on any deck foundation and 15ft setback on any pool.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy - Central Permitting