

April 6, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

William Mercer
6527 St Mary's Church Road
Lucama, NC 27851

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Tank Application # BRES2103-0069

Mr. Mercer:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary T

4. **Other – Under Review– Uncover the lids to the tanks and break free to allow to be accessed (required). If lids too large leave exposed and covered with boards and in a safe manner. The outlet sanitary tee shall be inspected to be intact and tank structurally sound (required). Applicant notified via phone.**

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting