



4400 NE 77th Ave, Suite 275  
 Vancouver, WA 98662  
 P: 360.566.7343  
 E: [starkd@starkfdn.com](mailto:starkd@starkfdn.com)

**STRUCTURAL CALCULATIONS**  
 PREPARED FOR  
**TARHEEL BASEMENT SYSTEMS**  
 FOR  
**ADAMS RESIDENCE**  
**FOUNDATION REPAIR**  
 386 CAMELIA RD  
 ANGIER, NC

**PROJECT NUMBER:** 21.083.TBS

**DATE:** March 19, 2021

**PROJECT MANAGER:** DANIEL STARK, P.E.

  
 Digitally signed by  
 Nathan Daniel Stark  
 Date: 2021.03.22 14:51:17 -07'00'



4400 NE 77th Ave, Suite 275  
Vancouver, WA 98662  
P: 360.566.7343  
E: [starkd@starkfdn.com](mailto:starkd@starkfdn.com)

March 19, 2021

Project No.: 21.083.TBS

Tonya Gunn  
Tarheel Basement Systems  
2910 Griffith Road  
Winston-Salem, North Carolina 27103

RE: Foundation repair - 386 Camelia Rd, Angier, NC

**PROJECT BACKGROUND**

We understand that the structure is a single-family residence and has experienced settlement at the front elevation of the structure . A recent floor level survey (attached) indicates as much as -1" of differential settlement may have occurred. It is our understanding that (2) 2 7/8 inch diameter push piers have been proposed to provide additional foundation support.



Image 1: Front Elevation

**GEOLOGIC SETTING**

The existing structure is located in Angier, NC. The geologic structure in the area is comprised of silty loam and the site is relatively flat. It is our opinion that the localized settlement is a result of improper foundation drainage and/or undersized footings. We believe that suitable support can be achieved by installing helical and/or push piers.


**SUMMARY**

The ultimate load requirement for the push piers is 20000 lbs, and based on the geologic setting, we expect the piers to achieve adequate capacity at approximately 8 – 25 feet. We recommend that the piers with a 2 7/8 inch shaft and be installed to a minimum depth of 8 feet and a minimum installation pressure of 2100 psi, or refusal, using a 9.62 square inch hydraulic ram.

Regards,



Daniel Stark, P.E.  
Stark Foundations





PROJECT

Foundation Underpinning  
386 Camelia Rd  
Angier, NC

Date: 19-Mar-21

Designed by: NDS

Project No.: 21.083.TBS

---

**Design Criteria**


---

## Code(s):

International Building Code (IBC) 2015/2018  
ASCE 7-10

## Design Loads:

## Dead:

Roof = 15 psf  
Chimney = 45 psf  
Third Floor = 15 psf  
Second Floor = 15 psf  
First Floor = 15 psf  
Walls = 50 psf  
8" Foundation Wall = 100 psf  
Soil = 110 psf

## Soil:

Allow Lateral Bearing Pressure = 200 psf/ft  
Active Pressure = 60 psf/ft

## Live:

Roof (snow) = 25 psf  
Third Floor = 40 psf  
Second Floor = 40 psf  
First Floor = 40 psf

## Wind: (not applicable)

Exposure = C  
Wind Speed, V = 120 mph  
Gust Effect Factor, G = 0.85  
Internal Pressure Coefficient,  $GC_{pi}$  = -0.18  
External Pressure Coefficient,  $C_p$  = 0.8

Risk Category = II  
 $K_{zt}$  = 1.0  
 $K_d$  = 0.85  
 $K_z$  = 0.98  
Height,  $h_z$  = 30 ft

## Design Wind Pressure:

where:  $p_w = q_z (GC_p - GC_{pi})$   
 $q_z = 0.00256 K_z K_{zt} K_d V^2$

## Design Load Combo = D + 0.6W

 $\omega = 0.6$ 

## Therefore:

$q_z = 30.7$  psf  
 $p_w = 26.4$  psf  
Factored Wind Pressure,  $p'_w = 15.8$  psf (say 16 psf)



PROJECT

Foundation Underpinning  
386 Camelia Rd  
Angier, NC

Date: 19-Mar-21

Designed by: NDS

Project No.: 21.083.TBS

**Push Pier Design - Worst Case**

## Vertical Design Loads:

## Tributary Widths:

Roof =	11	ft	----->	165	plf
Third Floor =	0	ft	----->	0	plf
Second Floor =	4	ft	----->	60	plf
First Floor =	4	ft	----->	60	plf
Walls =	12	ft	----->	600	plf
Foundation Wall (height) =	2	ft	----->	200	plf
Soil (height) =	0.5	ft	----->	55	plf
				$\Sigma DL =$	1140 plf

## Live:

Roof (snow) =	11	ft	----->	275	plf
Third Floor =	0	ft	----->	0	plf
Second Floor =	4	ft	----->	160	plf
First Floor =	4	ft	----->	160	plf
				$\Sigma LL =$	595 plf

Max Pier Spacing or Trib = 6 ft

## Pier Working Loads:

$P_{DL} =$	6840	lbs
$0.75 \cdot P_{LL} =$	2678	lbs
Working Load, $P_{TL} =$	10000	lbs
Ultimate Load, $P_{ULT} =$	20000	lbs

## Pier Design:

Pier Type: Push Pier

Bracket: PP21617-34      Bracket Cap = 29340 lbs      Therefore ok      Reference ICC report (attached)

Shaft Diameter: 2.875"

## Installation Pressure, P:

$$Q_{ult} = 2 (P_{TL})$$

20000 lbs


$Q_{ult} = A_{cyl} (P)$  where  $A_{cyl}$  = working area of the dual bore installation cylinder

$$A_{cyl} = 9.62 \text{ in}^2$$

Therefore,  $P_{REQ} = Q_{ult} / A_{cyl}$

2100 psi






LEGEND	
10K	INDICATES PUSH PIER & UNFACTORED DESIGN LOAD (KIPS). SEE DTL 2
■	

∟ (E) CRAWL SPACE





2 2 7/8"  $\phi$  PUSH PIER DETAIL  
SCALE: 1/2" = 1'-0"