

April 21<sup>st</sup>, 2021

Edmund Wentland  
2278 Elliott Bridge Rd  
Bunnlevel, NC 28323

**RE: Permit Application for: 2278 Elliott Bridge Rd**

Dear Ms. Gutierrez,

An attempt was made to evaluate your property for the purpose of issuing a Permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank, break seal and uncover D-Box.

2. Have system pumped out

3. Replace sanitary T

**4. Other – Pool has to be 15ft from septic and drain lines. Pool is on top of drain lines. Revision required.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

MO/kh

Copy - Central Permitting