

HTE #: BRES2104-0043

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: Henry Alarco Phone #: (919) 608-4656

Address: 80 Doonbeg Dr Fuquay Varina, NC 27526

Name of Mobile Home Park or S/D: Avery Pond S/D/ - Lot 160

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 80 Doonbeg Dr. (Chalybeate Rd. - SR 1429)

Purpose of Inspection: Deck 20' x 30' - Deck built onsite w/o permits. Drain lines marked via GPR. Original septic encroachment of deck (<5ft) present. Applicant/homeowner provided engineer letter on relocated deck foundation pillars to allow septic approval.

**The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.**

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

08/31/2021

Date