

May 17, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Justin Barton
18 Old Head Way
Fuquay-Varina, NC 27526

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Tank Application # BRES2105-0006

Ms. Barton:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other–Proposed deck not marked onsite. Existing septic tank probed and marked onsite with flagging. Deck shall be marked onsite and verified to meet 5ft setback. If proposed deck encroaches on 5ft setback deck shall be revised accordingly for approval. Reconfirm when properly marked or revise land use/site plan accordingly.

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting