



Permit Inspections Harnett County

Permit Number: BRES2105-0025

Description: **44x16 double decker Deck**

Applied: **5/6/2021**

Approved: **5/11/2021**

Site Address: **573 COACHMAN WAY**

Issued: **5/12/2021**

Finalized:

City, State Zip Code: **SANFORD, NC 27332**

Status: **ISSUED**

Applicant: **Viper Home Maintenance**

Parent Permit:

Owner: **MITCHEM JAMES JR**

Parent Project:

Contractor: **Viper Home Maintenance**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			OPEN FLOOR	Slade Burton Lawson III		
Notes:						
			ROUGH IN	Slade Burton Lawson III		
Notes:						
			FINAL**	Slade Burton Lawson III		eTRAKiT Inspection Request
Notes:						
	6/1/2021	6/1/2021	FOOTING	Slade Burton Lawson III	APPROVED	
Notes: Inspector SBL changed the inspection assignment from SBL to SPG spg changed Inspection Date/Time from 05/28/2021 to 06/01/2021						
	12/10/2021	12/10/2021	FINAL**	Steven Gazlay	DISAPPROVED	eTRAKiT Inspection Request
Notes: 12/9/2021 12:52 PM George Nilsen Contact Name: George Nilsen Site Address: 573 COACHMAN WAY Phone: 9199352827 e-Mail: gviper.nilsen2@gmail.com Inspector SBL changed the inspection assignment from SBL to SPG Provide lvl documentation. Handrails must be 34-38 measured at walkline. Provide engineering letter on over span girders and girder splice not bearing on posts, joists exceeding span, girders not supported on posts. Need 3 nails in ledger strip at joist location. Bottom steps cannot exceed the height of steps above.						

