


Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Ann & Britt Nylund PROPERTY LOCATION: 192 Mels Meadow Dr. (Christian Lt. Rd. - S
 SUBDIVISION _____ LOT # _____
 NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: _____
 Type of Structure: 40x30 Pool House
 Proposed Wastewater System Type: 25% Reduction Sys.
 Projected Daily Flow: 200 GPD
 Number of bedrooms: NA Number of Occupants: NA max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent:  Date: 05/27/2021 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Ann & Britt Nylund PROPERTY LOCATION: 192 Mels Meadow Dr. (Christian Lt. Rd.
 SUBDIVISION _____ LOT # _____
 Facility Type: 40x30 Pool House New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 200 GPD
 (See note below, if applicable) 25% Reduction System (Repair)

Installation Requirements/Conditions

| | | |
|--------------------------------------|---|---|
| Septic Tank Size <u>1000</u> gallons | Number of trenches <u>2</u> | Trench Spacing: <u>9</u> Feet on Center |
| Pump Tank Size _____ gallons | Exact length of each trench <u>75</u> feet | Soil Cover: <u>12</u> inches |
| | Trenches shall be installed on contour at a Maximum Trench Depth of: <u>24</u> inches | (Maximum soil cover shall not exceed 36" above the trench bottom) |
| | (Trench bottoms shall be level to +/-1/4" in all directions) | |

Pump Requirements: _____ ft. TDH vs. _____ GPM
 Aggregate Depth: NA inches below pipe
NA inches above pipe
NA inches total

Conditions: Gravity to D-Box Equal Distribution

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

***If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent:  Date: 05/27/2021
ANDREW CORN Construction Authorization Expiration Date: 05/27/2026

STD 2105-0015

STD 2105-0016

Application # BLES 2105-0034

Harnett County Department of Public Health Site Sketch

Property Location: Mels Meadow Drive (Christian Light Rd. - SR 1412)

Issued To: Nylund Family


Subdivision _____

Lot # _____

Authorized State Agent: _____

Andrew Curran
ANDREW CURRAN

Date: 05/27/2021



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.