## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 6180 NC210 ISSUED TO: Phil Holland SUBDIVISION REPAIR NEW X EXPANSION | Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 40'x50' storage Proposed Wastewater System Type: 25% Reduction System Projected Daily Flow: 240 Number of Occupants: Number of bedrooms: X No Basement Yes May be required based on final location and elevations of facilities × No Pump Required: Yes Type of Water Supply: Community Public Well Distance from well \_\_\_\_\_\_\_feet Permit valid for: Five years ■ No expiration Permit conditions: Facility to have kitchen and bath. System sized to accomadate 2 bedrooms. Date: 7/19/21 RC-17 Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the Issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Phil Holland PROPERTY LOCATION: 6180 NC210 LOT # SUBDIVISION Facility Type: 40'x50' storage Expansion Repair Basement Fixtures? Yes Basement? Yes X No Type of Wastewater System\*\* 25% Reduction System (Initial) Wastewater Flow: 240 GPD (See note below, if applicable ) 25 % Red Sys Number of trenches 2 Installation Requirements/Conditions Trench Spacing: 9 Feet on Center gallons Exact length of each trench 55 Septic Tank Size 1000 Trenches shall be installed on contour at a Soil Cover: 6-18 \_gallons Pump Tank Size \_\_\_\_\_ Maximum Trench Depth of: 18-30\* (Maximum soil cover shall not exceed inches (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) inches below pipe Pump Requirements: \_\_\_\_\_ft. TDH vs. \_ inches above pipe Conditions: See site sketch for specific ditch depths. inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions at the laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Date: 7/19/21 Authorized State Agent: \_ Construction Authorization Expiration Date: 7/19/26

## Harnett County Department of Public Health Site Sketch

Prope	rty Location: 6180 NC210		
Issued	To: Phil Holland	Subdivision	Lot #
Autho	rized State Agent:	exis Couver	*START LINES @ 24" DEEP.  CAN GO 36" DEEP AFTER  THE STEPDONN
202-0		EXIST IN HO'XS CONSTR	