

June 7, 2021

Devin Helfin

RE: Existing Tank Application #BRES2105-0070

Mr. Helfin

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal.

2. Have system pumped out

3. Replace Sanitary Tee with Filter

4. Other – Need to move house from proposed location because it will be on top of the drain lines for the septic system

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Program Specialist
Harnett County Department of Public Health

MO/KH

Copy - Central Permitting