



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

9/13/2024

SUBJECT: BRES2106-0007
BUILDING RESIDENTIAL

To: OLVERA ALVARO PACHECO

Here are the results of all Inspections located at **260 DARK WOOD DR:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:



Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Slade Burton Lawson III
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 7/2/2021
Completed Date/Time: 7/2/2021
Inspector: Slade Burton Lawson III
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 2/4/2022
Completed Date/Time: 2/4/2022
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Missing anchor bolts. Need 2" square washers on anchor bolts by garage door. Strap garage door header, midway of door to over top plate. Block seams in plywood within 3 foot of corners.