

July 2, 2021

Oscar Ramirez  
37 Bargain Ln  
Sanford, NC 27332

**RE: Existing Tank Application #BRES2106-0020**

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal.
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other – Have septic contractor inspect septic tank to determine condition (hand made), and if it is usable, then they need to add a sanitary T to the outlet pipe

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS  
Environmental Health Program Specialist  
Harnett County Department of Public Health

MO/KH  
Copy - Central Permitting