

June 24, 2021

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

Russell Duncan Jr.  
85 Cardona Court  
Fuquay-Varina NC 27526

ph: 910-893-7547  
fax: 910-893-9371

**RE: Existing Tank Application # BRES2106-0032**

Mr. Duncan:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

\_\_\_ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

\_\_\_ 2. Have system pumped out

\_\_\_ 3. Replace Sanitary T

**X 4. Other –Denial - Septic Encroachment. Proposed outdoor pavilion encroaches on existing septic field (see pictures). Proposed addition on top of septic area. Unable to approve. Only route for approval is to provide private soil scientist septic relocation proposal to relocate septic system.**

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc  
Copy - Central Permitting