

HTE# BZPS 2106-0057

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Southern Touch Homes PHONE # 919 639-4672

ADDRESS PO Box 2135 Angier N.C. 27501

NAME OF MOBILE HOME PARK OR S/D Brian Keith Meadows 6814

NAME OF OWNER (IF DIFFERENT) Dewey + Vicki STEPHENSON

ADDRESS OF OWNER (IF DIFFERENT) 1516 Forest SABA WAY Angier N.C. 27501

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1403 Harnett Central Rd

PURPOSE OF INSPECTION: 24x48 GARAGE

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

* Garage in Partial Repair Area
* 50% reduction Repair Required

BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM

AUTHORIZATION OF EXISTING SYSTEM

[Signature]
Signature of Environmental Health Specialist

7-7-21
Date