



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

12/16/2021

SUBJECT: BRES2106-0058
BUILDING RESIDENTIAL

To: RAYNOR BUILDERS INC

Here are the results of all Inspections located at **90 BEECHLEAF CT:**

Inspection Type: ROUGH IN
Scheduled Date/Time: 9/20/2021
Completed Date/Time: 9/20/2021
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to SPG
Ok to insulate. Missing outlet right of door. Secure Sheetrock to studs at closet. Need tempered window downstairs next to door.

Inspection Type: ROUGH IN
Scheduled Date/Time: 9/22/2021
Completed Date/Time: 9/22/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to SPG

Inspection Type: INSULATION
Scheduled Date/Time: 9/22/2021
Completed Date/Time: 9/22/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to SPG

Inspection Type: FINAL**
Scheduled Date/Time: 12/9/2021
Completed Date/Time: 12/9/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: Inspector SBL changed the inspection assignment from SBL to SPG

