



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

8/6/2021

SUBJECT: **BRES2106-0059**
BUILDING RESIDENTIAL

To: KW Quality Trades Inc.

Here are the results of all Inspections located at **351 SHERMAN RD:**

Inspection Type: ROUGH IN
Scheduled Date/Time: 7/16/2021
Completed Date/Time: 7/16/2021
Inspector: Ray Holder
Result: DISAPPROVED
Remarks:
Notes: Through bolt band board at house every 24" per code.

Inspection Type: FOOTING
Scheduled Date/Time: 7/16/2021
Completed Date/Time: 7/16/2021
Inspector: Ray Holder
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 7/21/2021
Completed Date/Time: 7/21/2021
Inspector: Ray Holder
Result: APPROVED
Remarks:
Notes: Look for ledger lok screws

Inspection Type: FINAL**
Scheduled Date/Time: 8/6/2021
Completed Date/Time: 8/6/2021
Inspector: Ray Holder
Result: APPROVED
Remarks:
Notes:

