

CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT


Name: (owner) Wellons Realty New Installation Septic Tank
 Property Location: SR# 1513 Repairs Nitrification Line
 Subdivision Meadowbrook II Lot # 13-14
 TAX ID# _____ Quadrant # _____
 Contractor: Don Gaddy Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other Infiltrator LWS-93-2-R1
 Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons
 Subsurface Drainage Field No. of ditches 4 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18 in.
 French Drain: _____ Linear feet

PERMIT NO. 11008 Date: 5-31-95
 Inspected by: Thomas J. Boyer R.S.
 Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Wellons Realty Inc. New Installation Septic Tank
 Property Location: SR# 1513 Repairs Nitrification Line

Subdivision Meadowbrook II Lot # 13-14

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 1.45 ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50+ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other Infiltrator 1WWS-93-2-R1

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18 in.

French Drain required: _____ Linear feet


This permit is subject to revocation if site plans or intended use change.

Date: 2-20-96

Signed: Thomas J. Bayu R.S.

Environmental Health Specialist

VOID AFTER 5 YEARS



Maintain Setbacks

* Note House placement
 Drivet House must be built in setbacks or permit will be revoked

12" cover required over system

Contractor to meet on site prior to installation

System flagged