

July 26, 2021

RAY RODRIGUE  
PO Box 416  
Bunnlevel, NC 28323

**RE: Existing Tank Application #BRES2107-0025**

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal. (\$25.00 *fee incurred*)

2. Have system pumped out

**3. Replace Sanitary Tee with Filter**

**4. Other – Have the existing shed moved off of the septic drain lines**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS  
Environmental Health Program Specialist  
Harnett County Department of Public Health

MO/KH  
Copy - Central Permitting