

July 28, 2021

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Fabian Ashley
368 Village Bend Drive
Fuquay-Varina NC 27526

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Tank Application # BRES2107-0027

Fabian Ashley:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – Septic Encroachment – Proposed deck encroaches on septic setbacks. Adjacent drain field marked onsite and applicant notified to review paperwork accordingly with a 5ft deck foundation setback. Revise site plan and land use accordingly.

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7547 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy - Central Permitting