

August 2, 2021

Anthony Womack
6249 Cool Springs Rd
Broadway, NC 27505

RE: Existing Tank Application #BRES2107-0052

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal. (\$25.00 *fee incurred*)
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other – Have septic contractor fix pipe from septic tank to drain field, have them accurately flag the drain field, and move outlet lid to make sure sanitary T is able to be seen**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Program Specialist
Harnett County Department of Public Health

MO/KH
Copy - Central Permitting