

August 24, 2021

Christopher Binkley
53 McNeill Mill Rd
Broadway, NC 27505

RE: Existing Tank Application #BRES2108-0017

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal. (\$25.00 *fee incurred*)

2. **Have system pumped out**

3. Replace Sanitary Tee with Filter

4. **Other – Have contractor determine why water is only 8 inches from the top of the riser**

Your application will be put on hold until the selected items above have been addressed.

When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Program Specialist
Harnett County Department of Public Health

MO/KH

Copy - Central Permitting