



Permit Inspections Harnett County

Permit Number: BRES2108-0041

Description: **covert ext scr to living space, small porch**

Applied: **8/20/2021**

Approved: **2/22/2022**

Site Address: **89 GILLIS CT**

Issued: **2/22/2022**

Finalized: **8/28/2023**

City, State Zip Code: **COATS, NC 27521**

Status: **FINALED**

Applicant: **POPE JEANNIE BULLOCK**

Parent Permit:

Owner: **POPE JEANNIE BULLOCK**

Parent Project:

Contractor: **Jerry Pounds Construction, Inc.**

Details:

Proposed Addition is on top of existing septic system. Can not approve, sent builder to SS to have new system and repair design.

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FOUNDATION	Deen Taylor		
Notes:						
			MONO SLAB	Deen Taylor		
Notes:						
			SLAB	Deen Taylor		
Notes:						
			UNDER SLAB TRADES	Deen Taylor		
Notes:						
			OPEN FLOOR	Deen Taylor		
Notes: Engineered for open post support. See plan						
			ROUGH IN REINSPECT	Deen Taylor		
Notes:						
	3/2/2022	3/2/2022	FOOTING	Deen Taylor	APPROVED	
Notes:						
	5/10/2022	5/11/2022	FOOTING	Deen Taylor	APPROVED	
Notes: cus request another inspection before pouring concrete						
	8/23/2022	8/23/2022	ROUGH IN	Deen Taylor	DISAPPROVED	
Notes: Window within 24 inches of door upstairs must be tempered. Top of gate must be 36 inches from walking service for upstairs deck.						





Permit Inspections

Harnett County

	9/8/2022	9/8/2022	INSULATION	Deen Taylor	APPROVED	
Notes:						
40	1/13/2022	1/13/2022	ENVIR OPERATIONS PERMIT	James Manhart	APPROVED	
Notes:						
50	8/25/2023	8/28/2023	FINAL**	Deen Taylor	APPROVED	
Notes:						

