



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

1/18/2022

**SUBJECT: BRES2108-0056**  
**BUILDING RESIDENTIAL**

To: HASENFUS JUSTIN BRADLY

Here are the results of all Inspections located at **703 ADCOCK RD:**

Inspection Type: BONDING  
Scheduled Date/Time: 10/5/2021  
Completed Date/Time: 10/5/2021  
Inspector: Steven Gazlay  
Result: FAIL W/ PENALTY  
Remarks: eTRAKiT Inspection Request  
Notes: 9/30/2021 5:12 PM K.M.S. Electrical  
After 12 if possible  
Contact Name: K.M.S. Electrical  
Site Address: 703 ADCOCK RD  
Phone: 9193534497  
e-Mail: dannyhash007@gmail.com

Work must be completed before scheduling inspections. Pool not installed.

Inspection Type: ELECTRICAL UNDERGROUND  
Scheduled Date/Time: 10/6/2021  
Completed Date/Time: 10/6/2021  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: BONDING  
Scheduled Date/Time: 10/22/2021  
Completed Date/Time: 10/22/2021  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 10/7/2021 10:21 AM K.M.S. Electrical

Contact Name: K.M.S. Electrical  
Site Address: 703 ADCOCK RD  
Phone: 9193534497  
e-Mail: dannyhash007@gmail.com

10/21/2021 10:22 AM K.M.S. Electrical  
If possible can you inspect it in the morning  
Contact Name: K.M.S. Electrical  
Site Address: 703 ADCOCK RD  
Phone: 9193534497  
e-Mail: dannyhash007@gmail.com

Backfill pool, then schedule bonding.

Inspection Type: ZONING  
Scheduled Date/Time: 11/8/2021  
Completed Date/Time: 11/8/2021 10:15 AM  
Inspector: Kyle Holder  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: BONDING  
Scheduled Date/Time: 11/9/2021  
Completed Date/Time: 11/9/2021  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 11/4/2021 7:37 PM K.M.S. Electrical

Contact Name: K.M.S. Electrical  
Site Address: 703 ADCOCK RD  
Phone: 9194993994  
e-Mail: dannyhash007@gmail.com

Reinforcing steel not bonded.



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: BONDING  
Scheduled Date/Time: 11/16/2021  
Completed Date/Time: 11/16/2021  
Inspector: Steven Gazlay  
Result: APPROVED W/EXC  
Remarks: eTRAKiT Inspection Request  
Notes: 11/12/2021 3:03 PM K.M.S. Electrical

Contact Name: K.M.S. Electrical  
Site Address: 703 ADCOCK RD  
Phone: 9194993994  
e-Mail: dannyhash007@gmail.com

Expose bonding tee at final inspection.

Inspection Type: BONDING  
Scheduled Date/Time: 1/14/2022  
Completed Date/Time: 1/14/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 1/14/2022  
Completed Date/Time: 1/14/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 9/30/2021 5:14 PM K.M.S. Electrical  
Afterb12 if possible  
Contact Name: K.M.S. Electrical  
Site Address: 703 ADCOCK RD  
Phone: 9193534497  
e-Mail: dannyhash007@gmail.com

