

September, 24th 2021

ph: 910-893-7547

fax: 910-893-9371

Darlin Guadalupe
210 Kinton Farm Rdg
Fuquay Varina, NC 27526

RE: Existing Tank Application # BRES2108-0060

Ms. Guadalupe,

An attempt was made to evaluate your property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal and D-Box (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other – Septic Encroachment - Lines located via GPR. Proposed building encroaches on bottom line. Applicant informed onsite to shift building back 10ft or move building above system in side yard. Revision required. Reconfirm when ready.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy - Central Permitting