

OPERATIONS PERMIT

Name: (owner) Stanil Bldrs New Installation Septic Tank
 Property Location: SR# 1430 Repairs Nitrification Line
 Subdivision Olive Branch Lot # 36
 TAX ID# _____ Quadrant # _____
 Contractor: Fred Stanil Registration # _____

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: _____ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 4 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 16-24 in.

French Drain: _____ Linear feet

Date: 2-29-00

PERMIT NO. 16134

Inspected by: Thomas J. Boyer R.S.
Environmental Health Specialist



IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Stancil Bldg. New Installation Septic Tank
 Property Location: SR# 1430 Repairs Nitrification Line

Subdivision Olive Branch Lot # 36

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 min ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain Required: _____ Linear feet

Date: 2/18/99

This permit is subject to revocation if site plans or intended use change.

Signed: Bryan McJannet R.S.
 Environmental Health Specialist

* Maintain setbacks
 * Risers & Filter will be needed

