



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

5/17/2023

SUBJECT: BRES2109-0011
BUILDING RESIDENTIAL

To: HENRICKSEN LEE

Here are the results of all Inspections located at **265 HIGHMEADOW DR:**

Inspection Type: ELECTRICAL UNDERGROUND
Scheduled Date/Time: 10/10/2022
Completed Date/Time: 10/10/2022
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: Electrical is covered need to uncover for inspection

Inspection Type: BONDING
Scheduled Date/Time: 10/10/2022
Completed Date/Time: 10/10/2022
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: Electrical is covered need to uncover for inspection and need to see Exponential ground wire per code.

Inspection Type: ELECTRICAL UNDERGROUND
Scheduled Date/Time: 10/18/2022
Completed Date/Time: 10/18/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: BONDING
Scheduled Date/Time: 10/18/2022
Completed Date/Time: 10/18/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ZONING
Scheduled Date/Time: 10/20/2022
Completed Date/Time: 10/20/2022 10:00 AM
Inspector: Kyle Holder
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 10/28/2022
Completed Date/Time: 10/28/2022
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Barrier requirements not met.

Inspection Type: FINAL**
Scheduled Date/Time: 3/16/2023
Completed Date/Time: 3/16/2023
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes: