

Enoch Engineers, P.A.

Consulting Engineers & Surveyors

1403 NC Highway 50 South
Benson, North Carolina 27504

Phone: (919) 894-5731
(919) 894-7765

Fax: (919) 894-8190

Email: general@enochengineers.com

Joe E. Godwin Sr., P.E., P.L.S.

Fleet Temple, P.E.

Jason E. Godwin, P.L.S.

April 21, 2021

Wellons Construction
510 North Powell Avenue
Dunn, North Carolina 28334

ATTN: Bobby Wellons

RE: Structural

Subject: Shelter; 6445 Highway 217
Linden, North Carolina 28356

To Whom It May Concern:

Enoch Engineers performed a structural evaluation of the shelter structure at the subject noted above on April 12th, 2021. This letter is to address and certify the drawings/plans submitted to Enoch Engineers P.A. for a farm use structure. The shelter structure in reference has been determined structurally stable to be used for farm storage and NOT for human habitation. The above level storage can contain a limit of 20 pounds per square foot of storage load.

If we may be of further assistance, please feel free to call.

Respectfully,



A circular professional seal for Joe E. Godwin Sr., P.E., North Carolina Professional Engineer No. 517. The seal is stamped over a handwritten signature and the date 4/21/21.

Joe E Godwin Sr., P.E.
Enoch Engineers, P.A.

JEG Sr. / BLH