

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

September 27th 2021

Epimenio Perez
404 Nicole Dr
Sanford, NC 27322

Re: Status of Improvement Permit Application-BRES2109-0028

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to accurately mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs brush and vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- The house needs to move back on the lot by 40 feet to avoid having the septic system going into soils that are not suitable, and to avoid a mound system on the side of the house.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Specialist
Harnett County Department of Public Health

MO/KH

Copy: Central Permitting