

September 30, 2021

James Tart
873 Sadler Rd
Dunn, NC 28334

Re: Status of Permit Application-BRES2109-0033

To whom it may concern,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are Set by surveyor need to be visible. (\$25.00 Fee incurred)
- 2. Use orange flags to mark house box.
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs cleared
- 5. Driveway not shown on site plan (Revision Required)
- 6. Backhoe pits required

X 7. Other- Site is predominantly present with unsuitable wet soils. Does not appear to be sufficient soil for septic area, septic repair area, and home/driveway. Soil scientist proposal and layout required to proceed. Additionally, property line shall be clearly marked by a surveyor or line of site cleared irons to iron. Additionally, insufficient site plan. Site plan is poorly drawn with unable to determine lot orientation. Site plan shows existing easements. Map shall be provided showing existing easements, locations, and proposed access driveway locations. Reconfirm when requirements met.

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy: Central Permitting