

Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Timothy B McNeill PROPERTY LOCATION: SR 1201 Ponderosa Rd
 SUBDIVISION _____ LOT # 1
 NEW REPAIR EXPANSION Relocation Site Improvements required prior to Construction Authorization Issuance: _____
 Type of Structure: SWMT 14x80
 Proposed Wastewater System Type: 25% REDUCTION
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: James E. Monahan Date: 9-30-21 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Timothy B McNeill PROPERTY LOCATION: SR 1201 Ponderosa Rd
 SUBDIVISION _____ LOT # 1
 Facility Type: Ex SWMT 14x80 New Expansion Repair Relocation
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction System (Box 4 + Infiltration) Wastewater Flow: 360 GPD
 (See note below, if applicable 25% Reduction System (Repair)
 Installation Requirements/Conditions
 Septic Tank Size 1000 gallons Number of trenches 3
 Pump Tank Size _____ gallons Exact length of each trench 86 feet Trench Spacing: 7 Feet on Center
 Pump Requirements: _____ ft. TDH vs. _____ GPM Soil Cover: 6 inches
 (Maximum soil cover shall not exceed 36" above the trench bottom)
 Conditions: USE A D-BOX Aggregate Depth: 6 inches below pipe
2 inches above pipe
12 inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Monahan Date: 9-30-21
 Construction Authorization Expiration Date: 9-30-24

Application # BZBS 2109-0038


Harnett County Department of Public Health Site Sketch

Property Location: SR 1201 Penducosa Rd

Issued To: Timothy B McNeill Subdivision _____ Lot # 1

Authorized State Agent: James E. Markant ~~IB~~ IBSAS Date: 9-30-21

- * NO WATER OR POWER LINES IN SYSTEM OR REPAIR AREA. RUN DOWN PROPERTY LINES 90° TO DWELLING
- * NO DRIVEWAYS IN SYSTEM OR REPAIR AREAS.
- * INFILTRATOR QUCK-4 PLUS IS REQUIRED.
- * FOLLOW CONSULTANTS LAYOUT. 18" MAX DETENT DEPTHS SOME TREES MAY NEED REMOVAL.



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.