

HTE #: Bres2110-0050

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Chris Rusznica

Phone #: 1-630-936-9622

Address: 602 Academy Dr, Northbrook, IL 60062

Name of Mobile Home Park or S/D: _____

Name of Owner (if different): Everette Coats

Address of Owner (if different): 1303 Creekview Ln, Linden (SR2039)

Property Location (State Road name and #): 1303 Creekview Ln, Linden (SR2039)

Purpose of Inspection: Addition of a 3 seasons room 14' x 12'

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM


Signature of Environmental Health Specialist

12-8-21
Date